



# South Mississippi Correctional Institution (Leakesville, MS) Clean Heat and Power System




## Project Profile

Project Overview:

Representatives of the Southeast CHP Regional Application Center (Southeast RAC) as well as representatives from the Mississippi State University Industrial Assessment Center (IAC) met with representatives from the South Mississippi Correctional Institution to discuss the possibility of a Clean Heat and Power (also known as Combined Heat and Power, CHP) applications. As part of the Southeast RAC technical assistance and outreach program, the Southeast RAC agreed to assist the MSU IAC in determining the feasibility of CHP applications.

A layout of the facility examined is as follows:


 Natural-gas Fired Boilers (2) Each 5.25 MMBtu/Hour 75 PSIG Min.	Warehouse and Warehouse Refrigeration <p style="text-align: right;">No Boiler Application</p>
Kitchen	Cooking Pots use Steam Dish Washing uses Steam <p style="text-align: right;">New Horizontal Ovens----Natural Gas</p>
Post Office <p style="text-align: right;">No Boiler Application</p>	Laundry Washing machines use a detergent that requires cold water. <p style="text-align: right;">Dryers use steam</p>

Space conditioning (heat) and potable water uses steam for the building.

Central Kitchen    SMCI

MSU IAC and Southeast RAC members made the following recommendations:

Replace one of the existing natural gas boilers with a wood-fired boiler and keep the remaining natural gas boiler to supplement the wood-fired boiler.



The system was modeled in U.S. Department of Energy (DOE) Steam System Assessment Tool (SSAT). The model is built using information provided by the staff at SMCI. The system model recommendation makes certain key assumptions. The first assumption is a direct replacement of the current natural gas boiler with a wood fired boiler system. The model also assumes a current average natural gas price of \$8.09/MMBtu and an average wood price of \$27.00/ton. The heating value of green wood is taken to be 5,251 Btu/lb. The results of the model are shown in the table below.

	<b>Current Option</b>	<b>Recommended Option</b>
<b>Fuel Cost (\$/yr)</b>	\$334,000	\$106,000
<b>Fuel Consumption</b>	4712.8 s.cu.ft./hr	0.4 ton/hr
<b>Fuel Cost (\$/MMBtu)</b>	8.09	2.57

The implementation of this recommendation includes the cost of the boiler and installation. The type and cost of a material handling system will be dependent upon fuel supply form and storage location. The implementation cost as determined by MSU IAC members is as follows (obtained from *2001 Means Mechanical Data*, plus 30% adjustment for inflation):

<b>Item</b>	<b>Cost</b>
1 - 5.4 MMBtu/hr solid fuel boiler with controls	\$34,320
Labor	\$5,330
<b>Total</b>	<b>\$39,650</b>

This implementation cost results in an overall simple payback of 0.2 years and it was therefore recommended that the Southern Mississippi Correctional Institution replace one of the existing natural gas boilers with a wood-fired boiler and use the additional natural gas boiler for supplemental purposes only.